



CTLCOIFAX.COM

Commercial Testing Laboratory, Inc.

514 Main Street
Phone: 715-962-3121

P.O. Box 526
Phone: 800-962-5227

Colfax, Wisconsin 54730
Fax: 715-962-4030

ANALYTICAL REPORT

Lewis Bjork, LLC
E7818 County Road E
Menomonie WI 54751

Report Number: 25015077 Page: 1
Sample Number: 25-C5814
Report Date: 7/22/25
Date Received: 7/11/25

Owner: [REDACTED]
Address: E4610 290th Ave
Dunn County

Collector: Dan
Date Sampled: 7/11/25
Time Sampled: 10:35

Sample Source: OSF

Date Analyzed: 7/11/25
Time Analyzed: 12:00

Total Coliform-Colilert: Present /100ml

Interpretation: Bacteriologically UNSAFE

Nitrate+Nitrite-N: 0.02 ppm

Nitrite-N: < 0.04 ppm

Nitrate-N: < 0.10 ppm
Above 10 ppm Nitrate-N exceeds the recommended Public
Drinking Water Standard.

Arsenic: < 1.2 ug/L
Above 10 ug/L exceeds the Maximum Contaminant Level (MCL)
in drinking water systems.

Wisconsin Unique Well Number: AAK642
Date of Well Completion: 9/ 9/21
ARSENIC PRESERVED AT LAB

Lab Manager: Angela Albrecht

WDATCP Lab Certification #105-19

DNR Lab FID #617013980

< Means "LESS THAN" Detectable Level